

**INTERNATIONAL JOURNAL OF ENGINEERING SCIENCES & MANAGEMENT**  
**OPTIMIZATION STUDIES OF ECONOMICAL PARAMETERS IN HYBRID**  
**RENEWABLE ENERGY SYSTEM**

<sup>1</sup>Priyanka Verma and <sup>2</sup>Hemant Verma

<sup>1</sup> M.Tech Scholar, Department of Electrical Engineering, SSTC, Bhilai (C.G.)

<sup>2</sup> Assistant Professor, Department of Electrical Engineering, SSTC, Bhilai (C.G.)

Corresponding author mail- priyanka1996@gmail.com

**ABSTRACT**

With the fast progression of renewable energy markets, the importance of combining different sources of power into a hybrid renewable energy system (HRES) has gained more attraction. These hybrid systems can overcome limitations of the individual generating technologies in terms of their fuel efficiency, economics, reliability and flexibility. One of the main concerns is the stochastic nature of photovoltaic (PV) and wind energy resources. Wind is often not correlated with load patterns and may be discarded some- times when abundantly available. Also, solar energy is only available during the day time. A hybrid energy system consisting of energy storage, renewable and nonrenewable generation can alleviate the issues associated with renewable uncertainties and fluctuations. Large number of random variables and parameters in a hybrid energy system requires an optimization that most efficiently sizes the hybrid system components to real- ize the economic, technical and designing objectives. This chapter provides an overview of optimal sizing and optimization algorithms for hybrid renewable energy systems as well as different objective functions considered for designing such systems.

**Keywords:** hybrid energy system, objectives, optimization, renewable energy, sizing

**INTRODUCTION**

Use of solar and wind power has become more and more significant, attractive and less expensive, since the oil crises in the early 1970s. Even though there is a need to use renewable energy sources, the main problem with it is the dependency on environmental conditions like solar irradiance and wind speed. The individual energy sources cannot provide continuous power supply to the load because of the uncertainty and on-and-off nature of the environmental conditions [1]. Combining intermittent renewable energy sources with other dispatch able sources of energy such as biogas and fuel cells as well as energy storage systems provides a solution to address this challenge. Hybrid renewable energy system (HRES) is a term to describe the combination of two or more renewable and nonrenewable energy sources. Basic components of such systems are power sources (wind turbine, diesel engine generator and solar arrays), the battery and the power management center, which regulates power production from each of the sources [1]. As an example of such systems, micro grid is an integrated energy system that includes energy resources, loads and storages. Micro grids found popularity over the years due to the needs for distributed generation and with the integration of HRESs including photovoltaic (PV) and wind generators as well as the battery storage devices. The micro grids have many benefits for both utility grids and customers, such as higher power quality, reduction in carbon emission, energy efficiency and reduced costs. Another capability of micro grids is islanding

which allows the micro grid to be disconnected from the utility grid in the case of upstream disturbances or voltage fluctuations [2].

Operating an HRES requires optimizing its performance while satisfying its physical and technical constraints. Therefore, optimization tools, techniques and applications have found popularity to achieve these goals [3].

#### Optimal sizing for hybrid renewable energy systems

HRESs require an optimal design for their component sizing to economically, efficiently and reliably meet the objectives outlined in Section 4. Table 1 provides examples of studies related to HRES optimization parameters evaluated along with details regarding the hybrid system components, their load characteristics and sizing.

**Table-1 Survey Optimized parameters for Hybrid Energy system**

References	Hybrid System	Load Specifications	Parameters Optimized
[4]	Wind/PV/Battery	225kW peak, 25 kW base	Size, NPC, LCOE.
[5]	Wind /PV/Micro Turbine/ Battery	1.5kW constant	Size, NPC, LCOE.
[6]	Wind/ PV/diesel/ Battery	26kW peak, 5kW base	Size, NPC, LCOE, Emission factor
[7]	Wind /PV/ Battery	1500W	Size, NPC, LCOE.
[8]	Wind/ diesel/ Battery	3.5kW peak, 0.25 kW base	NPC, LCOE, Emission factor
[9]	Wind/PV/Energy storage	1MW peak, 0.4 MW base	Size, NPC, LCOE.
[10]	Wind/PV/Energy storage	1MW constant	Size, NPC, LCOE.

#### Optimization objectives for HRESs

Various criteria are considered for optimal design and component sizing of HRESs. These criteria can be broadly categorized as economic and technical. Economic criteria are used to minimize costs of HRESs. Technical criteria include reliability, efficiency and environmental objectives to supply the load demand of HRESs at desired reliability levels with maximum efficiency and minimum greenhouse gas emissions. HRESs often times include higher capital costs and lower operation and maintenance (O&M) costs which require an optimization to determine the compromise solution between the costs and benefits. Cost optimization of hybrid renewable energy systems includes minimizing energy cost, net present cost (NPC) and any other costs associated with such systems.

a. Energy cost minimization

Several studies have investigated minimizing levelized cost of energy (LCE) for HRESs. LCE is the ratio of total cost of the hybrid system to the annual energy supplied by the system. Study of the related research works, with their objective functions and techniques used for optimization and their main findings is performed.

b. Net present cost minimization

Net present cost (NPC) of an HRES is defined as the total present value of the system that includes the initial cost of the system components as well as the replacement and maintenance cost within the project lifetime. The objective here is to minimize the NPC of HRESs. Study of the related research works, with their objective functions and techniques used for optimization and their main findings is performed.

c. Other cost-related optimization

Other cost-related optimizations include minimizing life cycle cost (LCC), levelized unit electricity cost (LUEC), annualized cost of the system (ACS), capital cost (CC) of the hybrid system, total cost of the system (TCS) and average generation cost (AGC).

## CONCLUSION

The study of various hybrid renewable energy systems is performed and the optimization parameters evaluated are presented and discussed. The main parameters are sizing, net present cost, levelized cost of energy and emission factors. Based on the site survey report the hybrid system is proposed and then the optimization is performed in HOMER pro software to check the feasibility of the proposed system to meet the electricity demand.

## REFERENCES

- [1] Shivarama Krishna K., Sathish Kumar K. A review on hybrid renewable energy systems. *Renewable and Sustainable Energy Reviews* 2015; 52: 907–916.
- [2] Parhizi S., Lotfi H., Khodaei A., Bahramirad S. State of the art in research on microgrids: a review. *IEEE Access* 2015; 3: 890–925.
- [3] Fathima A., Palanisamy K. Optimization in microgrids with hybrid energy systems – a review. *Renewable and Sustainable Energy Reviews* 2015; 45: 431–446.
- [4] Kalantar M., Mousavi S.M.G. Dynamic behaviour of a stand-alone hybrid power generation system of wind turbine, microturbine, solar array and battery storage. *Applied Energy* 2010; 87: 3051–3064.
- [5] Yang H., Zhou W., Lu L., Fang Z. Optimal sizing method for stand-alone hybrid solar–wind system with LPSP technology by using genetic algorithm. *Solar Energy* 2003; 82: 354–467.
- [6] Boonbumroong U., Pratinthong N., Thepa S., Jivacate C., Pridasawas W. PSO for ac-coupling standalone hybrid power system. *Solar Energy* 2011; 85: 560–569.
- [7] Hongxing Y., Zhou W., Chengzhi L. Optimal design and techno-economic analysis of a hybrid solar–wind power generation system. *Applied Energy* 2009; 86: 163–169.
- [8] Zhang X., Tan S.C., Li G., Li J., Feng Z. Components sizing of hybrid energy systems via the optimization of power dispatch simulations. *Energy* 2013; 52: 165–172.
- [9] Arabali A., Ghofrani M., Etezadi-Amoli M., Fadali M.S., Baghzouz Y. Genetic-algorithm-based optimization approach for energy management. *IEEE*

- Transactions on Power Delivery 2013; 28(1): 162–170.
- [10] Arabali A., Ghofrani M., Etezadi-Amoli M., Fadali M.S. Stochastic performance assessment and sizing for a hybrid power system of solar/wind/energy storage. IEEE Transactions on Sustainable Energy 2014; 5(2): 363–371.
- [11] Siddaiah R., Saini R. A review on planning, configurations, modeling and optimization techniques of hybrid renewable energy systems for off grid applications. Renewable and Sustainable Energy Reviews 2016; 58: 376–396.
- [12] Ramakumar R., Abouzahr M., Ashenay K. A knowledge-based approach to the design of integrated renewable energy systems. IEEE Transactions on Energy Conversion 1992; 7(4): 648–659.
- [13] Akella A.K., Sharma M.P., Raini R.P. Optimum utilization of renewable energy sources in a remote area. Renewable and Sustainable Energy Reviews 2007; 11(5): 894–908.
- [14] Hennet J.C., Samarakou M.T. Optimization of a combined wind and solar power plant. Energy Research 1986; 10(2): 181–188.
- [15] Gupta A., Saini R.P., Sharma M.P. Optimized application of hybrid renewable energy system in rural electrification. In: Proceedings of India International Conference on Power Electronics. IEEE, Chennai, India, 2006.
- [16] Kanase-Patil A.B., Saini R.P., Sharma M.P. Integrated renewable energy systems for off grid rural electrification of remote area. Renewable Energy 2010; 35(6): 1342–1349.
- [17] Nagabhushana A.C., Rohini R., Raju A.B. Economic analysis and comparison of pro- posed HRES for stand-alone applications at various places in Karnataka state. In: Proceedings of IEEE PES Innovative Smart Grid Technologies. IEEE, Kerala, India; 2011.
- [18] Ashok S. Optimized model for community-based hybrid energy system. Renewable Energy 2007; 32: 1155–1164.
- [19] El-Zeftawy A.A., Abou El-Ela A.A. Optimal planning of wind-diesel generation units in an isolated area. Electric Power Systems Research 1991; 22(1): 27–33.
- [20] Das T.K., Chakraborty D., Swapan S. Energy consumption and prospects for renewable energy technologies in an Indian village. Energy 1990; 15(5): 445–449.
- [21] Hochmut G.C.S. A combined optimization concept for the design and operation strategy of hybrid-PV energy systems. Solar Energy 1997; 61(2): 77–87.
- [22] Zhao B., Zhang X., Chen J., Wang C. Operation optimization of stand alone micro-grids considering life time characteristics of battery energy storage system. IEEE Transactions on Sustainable Energy 2013; 4(4): 934–943.
- [23] Liao G.C. Solve environmental economic dispatch of smart microgrid containing dis- tributed generation system—using chaotic quantum genetic algorithm. International Journal of Electrical Power and Energy Systems 2012; 43(1): 779–787.
- [24] Katsigiannis Y.A., Georgilakis P.S., Karapidakis E.S. Multi objective genetic algorithm solution to the optimum economic and environmental performance problem of small autonomous hybrid power systems with renewables. Renewable Power Generation 2010; 4(5): 404–419.
- [25] Abbes D., Martinez A., Champenois G. Eco-design optimisation of an autonomous hybrid wind–photovoltaic system with battery storage. IET Renewable Power Generation 2012; 6(5): 358–371.
- [26] Koutroulis E., Dionysian K., Antonis P., Kostas K. Methodology for optimal sizing of stand-alone photovoltaic/wind-generator systems using genetic algorithms. Solar Energy 2006; 80(9): 1072–1088.
- [27] Koutroulis E., Kolokotsa D. Design optimization of desalination systems power-supplied by PV and wind energy sources. Desalination 2010; 258: 171–181.

- [28] Zeng J., Li M., Liu J.F., Wu J., Ngan H.W. Operational optimization of a stand-alone hybrid renewable energy generation system based on an improved genetic algorithm. Proceedings of IEEE Conference, 2010.
- [29] Wang L., Singh C. Multi criteria design of hybrid power generation systems based on a modified particle swarm optimization algorithm. IEEE Transactions on Energy Conversion 2009; 24(1): 163–172.
- [30] Hakimi S.M., Moghaddas-Tafreshi S.M. Optimal sizing of a stand-alone hybrid power system via particle swarm optimization for Kanauji area in South-East of Iran. Renewable Energy 2009; 34(7): 1855–1862.